West Moors Memorial Hall & Social Club
Station Road
West Moors
Ferndown
Dorset
BH22 0HZ

Inspection Date: 11/05/2026

t: +44 (0)1202 84 96 95
e: safe@thefirepoint.co.uk
w: thefirepoint.co.uk
m: Unit 3 Old Manor Farm Buildings
187 Leigh Road
Wimborne
Dorset
BH21 2BT

The Firepoint
Trusted Fire Safety
Services | Supplies | Support

Duration Test:

Emergency Lighting Inspection Report

Area	Device type	Function	Status	Comments
Hall Entrance (external)	Bulkhead	180	Passed	
Hall Entrance (external)	Bulkhead	180	Passed	
Hall Entrance	Bulkhead	180	Passed	
Ladies W/C	Bulkhead	180	Failed	Failed duration
Gents W/C	Bulkhead	180	Passed	
Hall	Suspended Strip	180	Passed	
Hall	Suspended Strip	180	Passed	
Hall	Suspended Strip	180	Passed	
Hall	Suspended Strip	180	Passed	
Hall Front	Bulkhead	180	Passed	
Hall Front	Twinspot	180	Passed	
Hall Side	Bulkhead	180	Passed	
Hall Side	Twinspot	180	Failed	Failed duration
Hall Side	Bulkhead	180	Passed	
Hall Side	Twinspot	180	Failed	Failed duration
Hall to Circulation	Bulkhead	180	Passed	
Hall Fire exit External	Bulkhead	180	Passed	
Stage	Bulkhead	180	Passed	
Stage	Bulkhead	180	Passed	
Stage	Bulkhead	180	Passed	
Small Meeting Room	Bulkhead	180	Passed	
Small Meeting Room	Bulkhead	180	Passed	
Small Meeting Room	Bulkhead	180	Passed	
Stage Circulation Space	Ceiling Mount	180	Passed	
Stage Circulation Space	Ceiling Mount	180	Passed	
W/C Circulation Space	Ceiling Mount	180	Passed	
W/C Circulation Space	Ceiling Mount	180	Passed	
W/C Circulation Space	Ceiling Mount	180	Passed	
W/C Circulation Space	Ceiling Mount	180	Passed	
W/C Circulation Space	Ceiling Mount	180	Passed	
Side Fire Exit	Bulkhead	180	Passed	
Side Fire Exit External	Bulkhead	180	Passed	
Kitchen	Bulkhead	180	Passed	
Kitchen Circulation	Bulkhead	180	Passed	
Kitchen External	Bulkhead	180	Passed	
Social Club Fire Exit 1	Signbox	180	Passed	
Social Club Fire Exit 1	Signbox	180	Passed	
Social Club Fire Exit 2	Signbox	180	Passed	

BS 5306 Part 3 Portable Extinguisher Maintenance

Extinguisher Supplies

Quality Assured Fire Protection.

West Moors Memorial Hall & Social Club
Station Road
West Moors
Ferndown
Dorset
BH22 0HZ

Inspection Date: 11/05/2026

t: +44 (0)1202 84 96 95
e: safe@thefirepoint.co.uk
w: thefirepoint.co.uk
m: Unit 3 Old Manor Farm Buildings
187 Leigh Road
Wimborne
Dorset
BH21 2BT

The Firepoint
Trusted Fire Safety
Services | Supplies | Support

Social Club Pool Table	Bulkhead	180	Passed	
Social Club Pool Table	Bulkhead	180	Passed	
Social Club Office	Bulkhead	180	Passed	
Social Club Bar	Bulkhead	180	Passed	
Social Club Bar	Bulkhead	180	Passed	
Social Club Gents	Bulkhead	180	Passed	
Social Club Ladies	Bulkhead	180	Passed	

BS 5306 Part 3 Portable Extinguisher Maintenance

Extinguisher Supplies

Quality Assured Fire Protection.

The Firepoint is a trading name of 3crossfire Ltd | Registered in England, Reg No: 05677727 | Reg Office: 256 Ashley Road, Parkstone, Poole, BH14 9BZ